



- IF MULTIPLE TANKS ARE REQUIRED, THEY MUST BE MANIFOLDED TOGETHER INTO A SINGLE RISER.
- RISER SHALL BE A MINIMUM OF 1.5 x BUILDING HEIGHT AWAY FROM BUILDING, HOWEVER IT IS OFTEN AN ADVANTAGE FOR PROPOERTY OWNERS AND THE FIRE DEPARTMENT TO HAVE RISER INSTALLED A SIGNIFICANT DISTANCE AWAY FROM BUILDING (UP TO 100').
- PREFERRED METHOD FOR RISER LAYOUT IS TO CONTACT MARION COUNTY FIRE PREVENTION AT 291-8000.

EXAMPLE OF A SINGLE TANK SYSTEM

THIS DETAIL IS A GENERAL REPRESENTATION AND IS NOT TO SCALE

	MCBCC ADOPTED XX/XX/XX	<h3 style="margin: 0;">DRY HYDRANT DETAIL</h3>	7
	REVISION #		FR 001